

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Monitoring Reporting Requirements Not Met for
MASON WATER DEPT. WV3302708

Our water system violated drinking water monitoring requirements. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation.

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we did not monitor or test as required and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

At this time, there is nothing you need to do.

The table below lists the monitoring we did not conduct, other violations, and the associated compliance period.

| Monitoring Violation | Year-Fed Report # | Monitoring Frequency | Compliance Period |
|--------------------------------------------------------------------------------------------------------------|-------------------------|----------------------|--------------------------------------------------|
| 03, MONITORING, ROUTINE MAJOR NITRATE (NO3) Results Not Submitted | 2023-13076 2022-1322 | Quarterly | 2 nd Q 2023 2 nd Q 2022 |
| 03, MONITORING, ROUTINE MAJOR SODIUM Results Not Submitted | 2023-603721 | Triennially | 3 YR 2020-2022 |
| 3A, MONITORING, ROUTINE, MAJOR (RTCR) Valid Compliance Total Coliform Sample(s) Not Reported | 2022-603716 | Monthly | JAN 2022 |
| 52, ROUTINE TAP M/R (LCR) LEAD & COPPER RULE Required Lead & Copper Sample Results Not Submitted as Required | 2023-603722 | Semi-Annually | 6M 202207 |
| WB, CHLORINE, MOR Incomplete/Not submitted as Required or Missing Res. CI from Coliform Result | 2021-603709 | Monthly | SEP 2021 |

What happened? What is being done? (Describe corrective action)

See Attached paper.

For more information, please contact Aaron Woolard at 304-773-5200
(Contact Name) (Phone Number)
or PO Box 438 Mason WV 25260
(Mailing Address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Prepared: October 11, 2023

Date Distributed 12-6-23

Town of Mason WV3302708

03, Monitoring, Routine, Major Nitrate (NO3) Results Not Submitted—For the 2nd quarter of 2022 and 2023 our Nitrate samples were not taken. Nitrate samples for the 3rd and 4th quarter of 2022 were taken and results were in compliance, 3rd quarter nitrate samples for 2023 have been taken and we are awaiting results.

03, Monitoring, Routine, Major Sodium Results Not Submitted—Inorganic samples were taken and submitted but the lab didn't do the sodium test on the sample. Inorganic samples will be taken again during this period, and we will make sure the sodium test is taken with the rest of the inorganics.

3A, Monitoring, Routine, Major (RTCR) Valid Compliance Total Coliform Samples Not Reported—For January 2022 monthly total coliform samples were not taken. Samples have been taken monthly since and no coliform was detected.

52, Routine Tap M/R (LCR) Lead and Copper Rule Required Lead and Copper Sample Results Not Submitted as Required—An address was entered wrong on our sample report which caused

WB, Chlorine, MOR Incomplete/Not Submitted as required or missing Res. Cl from Coliform Result—Our monthly operational report was not submitted to the state. Report was completed and all chlorine results were in compliance. MOR has now been submitted